

# STUDYING THE PARAMETERS OF THE INSTALLATION WITH AN EXTENDED BARREL FOR EXTINGUISHING BY GEL-FORMING COMPOSITIONS

Ostapov Kostiantyn Mykhaylovych, PhD, Associate Professor of the Department

Senchykhin Yurii Mykolaiovych, PhD, Professor, Professor of the Department

Avetisian Vadym Heorhiiiovych, PhD, Associate Professor of the Department

Gritsina Ihor Mykolaiovych, PhD, Associate Professor, Deputy head of Department

National University of Civil Defence of Ukraine

*Ukraine*

Mathematical models of the consumption of the weight of GFC for extinguishing the simulated fire are shown in the form of a polynomial of the second degree, unknown coefficients of which were determined using the least squares methods. The following functional dependences were obtained:

– weight of GFC, [kg]:

$$y = 1.485 + 0.66575 \cdot x_1 + 5.3875 \cdot x_2 - 0.04375 \cdot x_1^2 - 0.41 \cdot x_1 \cdot x_2 - 6.875 \cdot x_2^2;$$

– extinguishing time, [s]:


$$y = 53.025 + 5.035 \cdot x_1 - 152 \cdot x_2 + 0.375 \cdot x_1^2 - 4.8 \cdot x_1 \cdot x_2 + 150 \cdot x_2^2.$$

In the following dependences, which are shown in Fig. 4, parameter  $x_1$  is the diameter of GFC drops, mm;  $x_2$  is the intensity of GFC supply, kg/s.

The use of the performed calculations in system  $R$  enabled assessing all coefficients of the regression according to Student criterion at the significance level  $\alpha=0.01$  and the number of degrees of freedom  $N_0=10$ . Confidence interval was  $\pm 0.125$  kg for the deviation of the weight of GFC and  $\pm 0.93$  s for the time of extinguishing the simulated fire.

The obtained models were verified for adequacy by Fisher criterion ( $F$ -criterion) at the significance level  $\alpha=0.01$ . Calculation value of  $F$ -criterion was 16.55 and 77.86 for two models, respectively, which is significantly higher than the tabular value  $F_*=5.67$  for significance level  $\alpha=0.01$  and degrees of freedom  $\kappa_1=4$ ,  $\kappa_2=11$ .

Therefore, all constructed models are adequate with guarantee of 99.0 %.



**Fig. 4. Diagrams of functional dependences: *a* – consumption of GFC weight for extinguishing the simulated fire; *b* – consumption of time for extinguishing the simulated fire**

The use of both these models, and tabular data of testing extinguishing of simulated fire 1A makes it possible to determine the rational values of dimensions of drops is 1 mm and intensity of GFC spraying is 0.6 kg/s.

#### **References:**

1. Ostapov K.M., Kirichenko I.K., Senchykhyn Y.M., Syrovyi V.V., Vorontsova D.V., Belikov A.S., Karasev A.G., Klymenko H.O., Rybalka E.A. (2019) Improvement of the installation with an extended barrel of cranked type used for fire extinguishing by gel-forming compositions. Eastern-European Journal of Enterprise Technologies. (100). P. 30–36. doi: 10.15587/1729-4061.2019.174592.